



May 14, 2009

ZOELLER PUMP CO.
CUSTOMER SERVICE AND TECHNICAL SUPPORT
3649 CANE RUN RD
LOUISVILLE KY 40211-1961

Re: Description: SEWAGE TANK TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: ZOELLER PUMP CO.
Product Name: SEPTIC TANK OUTLET FILTER
Model Number(s): 5000-0007
[MAX. DWF 4000 GDP]
Product File No: 20090123

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product must be installed in sewage treatment tanks approved by the Department of Commerce, Division of Safety and Buildings for use with this product.
- This product will prevent solids with a size greater than 1/16" in size from passing.
- This product may be installed as an outlet baffle of septic tanks or compartments that have a maximum daily flow rate of no more than 4000 gallons per day.

This approval supersedes the approval issued on 8/22/2003 under product file number 2003167. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030167.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov